

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1501:123 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: *Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

DESIGN: Models 106, followed by EX or DEX; followed by P, B or C; followed by ST, RIN or RINH; followed by A, B, C, G, M or R; followed by N5, R5, EK, S1 or G1 Adaptabeacon strobe and beacon lights. For use in Class I, Groups C and D; Class I, Division 2, Groups A, B, C and D; Class II, Groups E, F and G; Class III hazardous locations. For indoor or outdoor use, Type 3R and 4X.

Models 106DEX followed by P, B or C; followed by RINH; followed by A, B, C, G, M or R; followed by GW. For use in Class I, Groups C and D; Class II, Groups E, F and G; Class III hazardous locations. For indoor or outdoor use, Type 3R and 4X.

The devices employ the use of a pendant, ceiling or wall bracket connected to an enclosure of explosion-proof and dust-ignition-proof construction. The devices also employ a circuit board containing electrical components with a gas discharge flash tube or an incandescent/halogen lamp surrounded by a rotating reflector. Depending on the model, the flash tube or the rotating reflector are enclosed in a clear globe with an amber, blue, clear, green, magenta or red insert.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 120 VAC, 24 VDC, 240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as hazardous location strobe lights. Not to be used as a visual public mode alarm notification appliance and not suitable for hearing impaired application.

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager